

Certificate of Compliance

Certificate Number:

UL-US-2552017-0

Report Reference:

EX29259-20250128

Issue Date:

2025-01-29

Issued to:

Fierre Srl
VIA VIGENTINA 110/B PAVIA, PV 27100
Italy

This certificate confirms that representative samples of:
GFXX - Foam Monitors

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 162, Edition 8, Issue Date 2018-02-23, Revision Date 2022-06-10

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink that reads 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2552017-0
Report reference EX29259-20250128
Date 2025-01-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
FI-MM3-BZ	Foam Monitors
FI-MM3-BZ-A	Foam Monitors



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

File EX29259
Project 4791194390

January 28, 2025

REPORT

on

Foam Monitors

Fierre Srl
Pavia, Italy

Copyright © 2025 UL LLC

UL LLC authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion, provided it is reproduced in its entirety.

DESCRIPTION

PRODUCT COVERED:

USL-

Foam monitors for the application of firefighting foam solutions for models, types, inlet pressures, and solution discharge flow rates as shown:

Monitor Model	Nozzle Model	Type	Monitor Inlet Pressure, psi	Solution Discharge Flow Rate, gpm
FI-MM3-BZ	FI-BA-BZ-250	B, D	100	250
FI-MM3-BZ	FI-BA-BZ-350	B, D	100	350
FI-MM3-BZ	FI-BA-BZ-500	B, D	100	500
FI-MM3-BZ	FI-BA-BZ-750	B, D	100	750
FI-MM3-BZ	FI-BA-BZ-1000	B, D	100-145	845-1000
FI-MM3-BZ	FI-ABA-BZ-250	B, C	100	250
FI-MM3-BZ	FI-ABA-BZ-350	B, C	100	350
FI-MM3-BZ	FI-ABA-BZ-500	B, C	100	500
FI-MM3-BZ	FI-ABA-BZ-750	B, C	100	750
FI-MM3-BZ	FI-ABA-BZ-1000	B, C	100-145	845-1000
FI-MM3-BZ-A	FI-BA-BZ-250	A, D	100	250
FI-MM3-BZ-A	FI-BA-BZ-350	A, D	100	350
FI-MM3-BZ-A	FI-BA-BZ-500	A, D	100	500
FI-MM3-BZ-A	FI-BA-BZ-750	A, D	100	750
FI-MM3-BZ-A	FI-BA-BZ-1000	A, D	100-145	845-1000
FI-MM3-BZ-A	FI-ABA-BZ-250	A, C	100	250
FI-MM3-BZ-A	FI-ABA-BZ-350	A, C	100	350
FI-MM3-BZ-A	FI-ABA-BZ-500	A, C	100	500
FI-MM3-BZ-A	FI-ABA-BZ-750	A, C	100	750
FI-MM3-BZ-A	FI-ABA-BZ-1000	A, C	100-145	845-1000

A - Oscillating B - Non-oscillating C - Self-inducting D - Non-self-inducting

Refer to the individual foam concentrate Listings for operating limitations with specific combinations of foam concentrates and monitors.

USE:

The products covered by this Report are for use in accordance with the respective National Fire Protection Association Standards.